

PUBLIC HEALTH ENGINEERING DEPARTMENT

Water Quality Test Report

Division Name :- P. H. Division, Sitamarhi

District Name : Sitamarhi

Month : March

Name of School--Holy mary international school

Sl. No.	Testing Date	Block	Panchayat	Location	Village	Source	pH	Turb.	Cond.	TDS	TH	Ca	Mg	Cl	Alk	Fe	Remarks
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	23
1	29.03.2026	Dumra	Bhopp bhairo	Holy mary international school,Bhopp bhairo	Bhup bhairo	Submersible	7.25	3.5	330	215	185	45	25	46	198	0.3	Safe
Desirable Limit *							6.5-8.5	1.0	-	500	200	75	30	250	200	0.3	
Permissible Limit* in absence source (IS 10500-2012 - 2nd Revision							NR	5.0		2000	600	200	100	1000	600	1	

Note: (1) Drinking Water Specification First Revision -IS:10500:2012, Edition 2.2(2003-09,12,20)(Reaffirmed1993), (2) BDL = Below Detection Limit, (3)NR = No Relaxation, (4) ND = Not Done.

(a) Throughout any year, 95% of the samples should not contain coliform organisms in 100ml, (b) No sample should contain more than 10 coliform organisms per 100ml,

(c) Coliform organisms should not be detected in 100ml of any two consecutive samples.

Copy forwarded for information to: (i) Consultant Water Quality Cell, PHED, Govt. of Bihar, (ii) Director, Water Quality Cell, PHED, Govt. of Bihar, (iii) SLWTL, PHED, Govt. of Bihar.

*Man*  
02/04/2026  
S.D.O.  
P.H. SUB DIVISION  
SITAMARHI

*Principal*  
Principal  
Holy Mary International School  
CBSE Affiliation No 330988  
Bhopp Bhairo, Chandni Chowk, Papan Road  
Sitamarhi-843302

*Manager*  
Manager  
Holy Mary International School  
Bhopp Bhairo, Chandni Chowk, Papan Road  
Sitamarhi- 843319

*Chemist*  
31/3/2026  
Chemist  
P.h Division sitamarhi  
CHEMIST  
DIVISION SITAMARHI

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 92

Dated: 02.04.2026

It is certified that an inspection team headed by Assistant Engineer P.H. Sub. Division Sitamarhi

(Name of Officers with designation) from P.H. Division Sitamarhi PHED

inspected the Holy Mary International School, Bhoop Bhairo, Chandni Chowk

(Name & Address of the school) on 25.03.2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. dated

of District Water Testing Lab. Sitamarhi (PHED Lab) certified that the

Holy Mary International School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till One Year

Signature with Seal:

Name

Designation

Name & Address of the Office / Department :

Man  
02/04/2026


S.D.O.

P.H. SUB DIVISION

SITAMARHI

To Holy Mary International School,  
Bhoop Bhairo, Chandni Chowk  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

  
Principal  
Holy Mary International School  
CBSE Affiliation No. 330988  
Bhoop Bhairo, Chandni Chowk, Papan Road  
Sitamarhi-843302

  
Manager  
Holy Mary International School  
Bhoop Bhairo, Chandni Chowk, Papan Road  
Sitamarhi-843319